

RESOLUTION 16-160


**A RESOLUTION TO APPROVE REPLACEMENT OF HVAC AND
DUCTWORK IN CONCURRENCE WITH MOLD REMEDIATION AT FIRE
STATION 3**

WHEREAS, the Spring Hill Fire Department detected mold in Station 3 and is required to replace HVAC unit and ductwork; and

WHEREAS, City Staff advertised and accepted proposals from qualified contractors on October 14, 2016 has made a recommendation.


NOW, THEREFORE BE IT RESOLVED, that the City of Spring Hill authorizes the replacement of HVAC and Ductwork in Fire Station 3 from Copeland and Son Heating and Air in the amount of \$51,100.00, as recommended by the Budget and Finance Advisory Committee on on November 7, 2016.

Passed and adopted by the Board of Mayor and Aldermen of the City of Spring Hill, Tennessee on the 21st day of November, 2016.




Rick Graham, Mayor

ATTEST:



April Goad, City Recorder

LEGAL FORM APPROVED:



Patrick Carter, City Attorney



REQUEST: *Approval of Resolution 16-160*

SUBMITTED BY: Terry W Hood, Fire Chief
City Staff, Department and Title

DATE: 11/01/2016

RE: Mold Remediation of Station 3 Part 2

ATTACHMENTS: Quote from Copeland & Son Air Conditioning and Heating
Services

PURPOSE:

Mold remediation of Station 3.

BACKGROUND:

Due to the poor air circulation of the air system, mold keeps accumulating in the ventilation and around the air vents in the station due to excess moisture. To prevent this from happening again, we need a new air system in the station and insulation in the attic.

FINANCIAL IMPACT:

The bid came in at \$51,100. This is to come out of our Fire Department budget. This was not accounted for in the budget.

STAFF RECOMMENDATION:

Favorable Recommendation

ACTION REQUIRED (INCLUDE DEADLINE /PRIORITY):