

RESOLUTION 17-64

**A RESOLUTION TO AUTHORIZE THE EMERGENCY PURCHASE OF
RAW WATER INTAKE GENERATOR TRANSFER SWITCH**

WHEREAS, due to a lightening surge the Transfer Switch at the Raw Water Intake is in need of repair or replacement; and

WHEREAS, technicians have determined two components are damaged and possible more; and recommended the transfer switch be replaced; and


WHEREAS, a quote was received on June 13, 2017; and

WHEREAS, this generator transfer switch is a critical component of the water system; and

WHEREAS, the City of Spring Hill, Board of Mayor and Alderman allocated \$50,000.00 in funds for repair and maintenance in the 2017-2018 fiscal year budget.

NOW, THEREFORE, BE IT RESOLVED, that the City of Spring Hill Board of Mayor and Aldermen authorizes the emergency purchase of raw water intake generator transfer switch in the amount of \$14,515.80.

Passed and adopted by the Board of Mayor and Aldermen of the City of Spring Hill, Tennessee, on the 19th day of June 2017.




Rick Graham, Mayor

ATTEST:



April Goad, City Recorder

LEGAL FORM APPROVED:



Patrick Carter, City Attorney



REQUEST: *Approval of Resolution 17-64*
SUBMITTED BY: Victor Lay, City Administrator
Caryl Giles, Water Plant, Superintendent
DATE: 6/14/2017
RE: Emergency Replacement of Raw Water Intake Generator
Transfer Switch
ATTACHMENTS: Estimate

PURPOSE:

This replacement of the Raw Water Intake Generator Transfer Switch is necessary due to a lightening surge.

BACKGROUND:

During a storm on April 19, 2017, a power surge damaged this unit. Operators discovered this during a power outage on May 4, 2017. Technicians have determined two components are bad. These two pieces will cost approximately \$11,000.00, plus an estimated \$2,000.00 in labor. Once these are in place there could very well be additional damage. The cost estimate for a new transfer switch, including labor is 14,515.80. (See Attachment) Reduction could happen if the full two days are not needed for the repair.

We have filed an insurance claim for this unit.

FINANCIAL IMPACT:

Replacement cost is \$14,515.80. This cost has been budgeted in the 2017-2018 year in a repair and maintenance line item, 410-52110-262

STAFF RECOMMENDATION:

Favorable Recommendation

ACTION REQUIRED (INCLUDE DEADLINE /PRIORITY):

ADvanced
PROfessional Generator Services...

Emergency Power Systems

P.O. Box 244

Joelton, TN 37080-0244

615-826-2210 or (866)-826-2210 Toll free Fax: 1-866-373-5361

adprogen@comcast.net

Estimate

Date	Estimate #
6/13/2017	688E

Name / Address
City of Spring Hill PO Box 789 Spring Hill, TN 37174

Ship To
Raw Water Intake 2061 Carpenter's Bridge Rd Spring Hill, TN 37174 Kohler M/N: 400REOZD S/N: 0732443 Gen# 7

P.O. No.	Terms	Due Date	Rep	Account #	Project	Other
	Due upon receipt	6/13/2017		*** SEE NOTES...		

Item	Description	Qty	Total
ATS	Series 3 ATS Transfer Switch	1	9,084.80
Outside Services	Electrician for electrical 2 men to days	1	2,650.00
Labor - Tech 1	Labor 2 men 2 days	1	2,500.00
Freight	Freight Charge	1	231.00
supplies	Remove bad ATS and wiring , Install Delayed Transition Series 3 ATS . Misc. Supplies, *** 4 to 6 weeks delivery on ATS**	1	50.00

Thank you for your business. We appreciate the opportunity to serve you.		Subtotal	\$14,515.80
P.O. # _____		Sales Tax (9.25%)	\$0.00
		Total	\$14,515.80

Date: _____

Signature _____